



**lang  
structural  
engineering  
inc.**

July 28, 2016

To Whom It May Concern

Re: BW Creative Railing Systems  
Frameless Glass Railing – Top Mount and Fascia Mount

Dear Madam/Sir:

In January 2015, Intertek Testing Services NA Ltd. (Intertek) conducted a test program for the ProBuilt Frameless Railing System provided by BW Creative Railing Systems. Results of the test program show that the ProBuilt Frameless Railing System is in compliance with the following requirements:

**2015 International Building Code**

|                  |                      |
|------------------|----------------------|
| Section 1015     | Guards               |
| Section 1607.8.1 | Handrails and Guards |

**2015 International Residential Code**

|                |                                 |
|----------------|---------------------------------|
| Section R301.5 | Live Loads                      |
| Section R308   | Glazing                         |
| Section R312   | Guards & Window Fall Protection |

Furthermore, all fastener connections represented on the ProBuilt Frameless Railing System Top Mount Connections and Fascia Mount Connections sealed drawings, dated July 28, 2016, are in compliance with the aforementioned building codes load requirements.

Yours truly,  
**LANG STRUCTURAL ENGINEERING INC.**

Bill Louwerse, PE  
BL/jk



EXPIRES 09/30/2017



EXPIRES 04/03/2017